

## **ADDENDUM #2 TO SPEC. 05-289**

**November 23, 2005**

### **Demolition of Five (5) Buildings on or about 48<sup>th</sup> & 'O' Streets**

---

Addendum #2 to Spec. 05-289 for above project to be opened on Wednesday, November 30, 2005 at 12:00 noon. **Any and all additional questions need to be in writing to Vince Mejer in the Purchasing Department by noon, Wednesday, November 23, 2005. No questions will be answered after this time.** Vince's fax number is 441-6513 or his e-mail is [vmejer@lincoln.ne.gov](mailto:vmejer@lincoln.ne.gov).  
The following questions were received:

- What are the compaction requirements for the backfill of the building voids?  
All compaction shall be 92% standard density by standard proctor with moisture as necessary.
- Is there a slope requirement for grading?  
Slopes shall not be steeper than 3:1.
- Is it possible to get a temporary fire hydrant device to keep debris wet?  
For bidding purposes, bidders shall assume they have two options: using the hydrant located in the southeast corner of the intersection of 48<sup>th</sup> & 'M' or using the service connections at the buildings for water supply.

All other terms and conditions to remain unchanged.

Dated this 23<sup>th</sup> day of November, 2005

Purchasing Department

Vince M. Mejer  
Purchasing Agent